



If during post grouting inspection, some vents are slightly low in grout, is it ok to add more grout?

Yes, during post-grout inspection any voids that are found, or vents that are low, should be filled. The same grout should be used.