



What if the duct separated during concrete placement?

If the duct was separated and blocked with concrete, it would probably require a substantial concrete removal and repair unless it can be reached from either end. In some cases, may be able to install strands in adjacent tendons or add tendons to make up for the issue.